



District of Invermere

914 8th Ave PO Box 339
Invermere, BC V0A 1K0

ADDENDUM.05

Date:	October 6, 2026
Title:	Fort Point over CPKC Railway - Rehabilitation
BC Bid Opportunity ID:	233854
Contact:	Justin Patterson, engtech@invermere.net

This Addendum is issued prior to RFP Closing, in accordance with the RFP Documents and shall be considered an integral part of the Contract Documents, read together with the Drawings, Specifications and Addenda previously issued and with all subsequent Addenda.

Changes to Contract Documents:

1. Special Provision 5.07 Demolition of Existing Bridge

Add the following to Clause c) Execution:

The Contractor shall provide adequate shoring or bracing to maintain the stability and alignment of the timber substructure during demolition of the existing bridge.

2. Special Provision 5.08 Construction of Replacement Superstructure

Add the following to Clause c) Execution:

The Contractor shall provide adequate shoring or bracing to maintain the stability and alignment of the timber substructure during construction of the replacement superstructure.

3. Special Provision 5.16 Supply and Fabrication of Miscellaneous Steelwork

Revise 2nd paragraph to be:

All steel components shall be either:

- Type A or AT
- Type W or WT with hot-dipped galvanised coating.

4. Special Provision 5.23 Approach Road Paving



District of Invermere

914 8th Ave PO Box 339
Invermere, BC V0A 1K0

Revise 2nd paragraph to be:

Where the new grade is less than 100mm higher than the old grade, asphalt pavement shall be placed over the old pavement with a minimum depth of 40mm of new asphalt. Side edges shall be feathered. Tie-in to existing pavement shall be sawcut.

Revise 3rd paragraph to be:

Where the new grade is more than 100mm higher than the old grade, or where it is lower, the old pavement shall be removed. Sawcut at tie-in to existing pavement. The roadway shall be built up with select granular sub-base, 200mm of well-graded base course and asphalt pavement.

5. Section 01 10 01 General Requirements

1.3.3 Record Drawings & Operation and Maintenance Manuals. Revise bullet 4 to be:

- .4 On completion of the Work submit record documents to the Consultant. Record documents shall consist of:
 1. Record drawings prepared by the Contractors Specialty Engineer incorporating all changes and RFI responses from the construction. Record drawings shall be authenticated by the Specialty Engineer.
 2. Construction correspondence including all RFI, change documents, non-conformance reports etc.
 3. Submittals and shop drawings.
 4. QC inspection and testing records.

6. Section 01 10 01 General Requirements

1.3.7 Shop Drawings. Revise bullet 1 to be:

- .1 Submit a digital PDF version of completed shop drawings for each requirement requested in the Specifications or as the Consultant may reasonably request. For elements designed or specified by the Specialty Engineer, the shop drawings shall be stamped by the Specialty Engineer as evidence of their review and approval of the shop drawing prior to submission to the Consultant.

This Addendum forms part of the Proposal Documents and modifies the original RFP.

All other terms, conditions, and submission requirements remain unchanged.

Bidders must acknowledge receipt of **Addendum.05** in their Proposal submission.